### DOCUMENTATION SHEET

Steel Spring Isolators SO4





The open spring captive isolators, type SO, are designed for those applications where a limitation of isolator displacements is requested. The captive isolators are intended as a fixture or displacement limiter for a short term period, for instance during transportation of a resilient isolated installation. A further reduction of the installation displacements can be achieved with the additional installation of spring hanger units.

# Applications

- Generator sets
- Emergency power supplies
- DC-AC converters
- Industrial fans
- · Air-handling units

- Air-conditioning machines
- Compressor packages
- Electrical equipment
- Refrigerators
- Cooler units







# **Rubber Design** vibration and noise control

Туре	Cz [N/mm]	Cx, y [N/mm] at preferential load	Fz max [N]	Fz preferential [N]
SO4-1200	210,4	157,8	5345	4597
SO4-1400	245,3	177,4	6231	5381
SO4-1600	280,2	197,0	7117	6165
SO4-1800	315,2	230,5	8006	6934
SO4-2000	350,2	264,0	8896	7704
SO4-2300	402,8	300,4	10230	8860
SO4-2600	455,3	336,8	11565	10017
SO4-2900	507,9	365,4	12900	11173
SO4-3200	560,4	394,0	14234	12329
SO4-4000	700,8	504,2	17800	15400
SO4-5200	1214,7	766,0	23140	19900
SO4-6300	2031,5	1157,8	28906	24860
CHARACTERISTICS				

## Isolator selection

This described isolator selection is based on the vertical load of the isolators, if required seismic and 6 DOF calculations can be performed by our specialists.

- 1. Determine the total weight of the machine to be isolated, including work load
- 2. Determine the position of the combined centre of gravity in horizontal and vertical planes
- 3. Decide the number of isolators and the positions where the isolators are to be placed relative to the combined centre of gravity
- 4. Calculate the load per isolator
- 5. Select with the help of the preferential load in the table the suitable type of mounting

We recommend selection of the isolators be made with the load per isolator within + or - 10% of the preferential load. The static deflection of the isolator is calculated by dividing the load per isolator by the stiffness Cz given in the table for the selected isolator.

### Rubber Design B.V.

Industrieweg 21 2995BE Heerjansdam The Netherlands Phone: +31 (0)78 677 87 78 Email: info@rubberdesign.nl Web: www.rubberdesign.nl

